

PETROSAFE

Petroleum Safety & Environmental Services Co.
An Egyptian Oil Sector Company



بترو سيف

شركة الخدمات البترولية للسلامة والبيئة
إحدى شركات قطاع البترول



The Egyptian Natural Gas Holding Company "EGAS"








Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction Station



Prepared By
Petroleum Safety and Environmental Services Company
PETROSAFE

November 2018

Document Title: Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction & Metering Station

Title	Quantitative Risk Assessment Study For Farshout New Pressure Reduction Station – Qena Governorate		
Customer	Egyptian Natural Gas Holding Company "EGAS"		
Customer Reference	EGAS/QRA/02/2015-MG/MS		
Confidentiality, Copyright and Reproduction	This document has been prepared by PETROSAFE in connection with a contract to supply services and is submitted only on the basis of strict confidentiality. The contents must not be disclosed to third parties other than in accordance with the terms of the contract.		
Report Number	EGAS.HSE.QRA.Study.012/Farshout-ReGas/PRMS.No.09/2018/QRA/MG/MS/WS-DNV-PHAST.7.21/UAN.158,877-PETROSAFE-Final.Report-Rev.00		
Report Status	Revision 0		
	<p>PETROSAFE 6w/4 Hassan Nassar St. - Takseem El-Laselky - New Maadi, Cairo, Egypt Telephone: +(202) 2517 6935 / 2517 6936 / 2517 6937 Facsimile: +(202) 2517 6938 / 2517 6958 e-mail: mohamed.ghazaly@petrosafe.com.eg mohamed.samy@petrosafe.com.eg</p>		
Team Work	Name	Signature	Date
	Chem. Wael Said Audit. & Insp. Dept. Head	 PETROSAFE	29/10/2018
	Chem. Mohamad Samy Loss Prev. & Cont. Dept. Head	 PETROSAFE	01/11/2018
	Geo. Mohamad Al-Ghazaly Saf. & Env. Affairs Gen. Mgr.	 PETROSAFE	05/11/2018
Reviewed by	Dr. Emad Kelany Safety Asst. Gen. Mgr.	 EGAS	/11/2018
	Eng. Ahmad Farag World Bank Project Gen. Mgr.	 EGAS	/11/2018
Approved by	Sameh Abd Al Razek Asst. Chairman for Health & Safety	 EGAS	/11/2018
	Eng. Mostafa Helal Vice Chairman for Planning & Gas Projects	 EGAS	/11/2018
Distribution	<ul style="list-style-type: none"> Client: EGAS File: EGAS / PETROSAFE Library: EGAS / PETROSAFE 		



CONTENTS

Executive Summary	08/107
Introduction	17/107
Technical Definitions	18/107
Objectives	23/107
Quantitative Risk Assessment Study Scope	24/107
Quantitative Risk Assessment "QRA" Studies	25/107
Method of Assessment	25/107
<i>1.0- General Method Used</i>	25/107
<i>2.0- Risk Assessment</i>	25/107
Modeling the Consequences	27/107
Criterion for Risk Tolerability	28/107
Personnel Vulnerability and Structural Damage	31/107
Quantification of the Frequency of Occurrence	34/107
Identification of Scenarios Leading to Selected Failures	34/107
Relevant Weather Data for the Study	35/107
- Weather Data	35/107
- Stability Categories	39/107
Farshout PRMS Description	40/107
Background	40/107
The PRMS & Off-Take Location Coordinates	40/107
PRMS Brief Description and Components	40/107
Pressure Reduction and Metering Station (PRMS)	45/107
Pressure Reduction Station Mechanical Works	45/107
Filtration Stage	45/107
Heating Stage	45/107
Reduction Stage	45/107
Measuring Stage	46/107

Document Title: Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction & Metering Station

Odorizing Stage	46/107
Outlet Stage	46/107
Operating Philosophy and Control	46/107
Shutdown and Isolation Philosophy	46/107
Gas Odorant Specifications	46/107
Health Hazards	47/107
Inhalation	47/107
Skin Contact	47/107
Eye Contact	47/107
Ingestion	47/107
Hygiene Standards and Limits	47/107
Fire and Explosion Hazards	49/107
Fire Fighting and Protection Systems and Facilities	48/107
Emergency Response Plan "ERP"	48/107
Analytical Results of Consequence Modeling	49/107
1.0- Pressure Reduction Station Inlet Pipeline (4 inch)	49/107
1/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release	49/107
1/2- Consequence Modeling for 2 inch (Half Rup.) Gas Release	52/107
1/3- Consequence Modeling for 4 inch (Full Rup.) Gas Release	56/107
2.0- Pressure Reduction Station Outlet Pipeline (10 inch)	60/107
2/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release	60/107
2/2- Consequence Modeling for 4 inch (Half Rup.) Gas Release	63/107
2/3- Consequence Modeling for 10 inch (Full Rup.) Gas Release	67/107
3.0- Pressure Reduction Station Odorant Tank (Spotleak)	72/107

4.0- Pressure Reduction Station Off-take Pipeline (4 inch)	78/107
4/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release	78/107
4/2- Consequence Modeling for 2 inch (Half Rup.) Gas Release	81/107
4/3- Consequence Modeling for 4 inch (Full Rup.) Gas Release	84/107
Individual Risk Evaluation	87/107
• Risk Calculation	87/107
• Event Tree Analysis	90/107
Summary of Modeling Results and Conclusion	101/107
Recommendations	107/107

Tables		
Table (1)	Description of Modeling of the Different Scenario	27/107
Table (2)	Proposed Individual Risk (IR) Criteria (per person/year)	29/107
Table (3)	Criteria for Personnel Vulnerability and Structural Damage	31/107
Table (4)	Heat Radiation Effects on Structures (World Bank)	32/107
Table (5)	Heat Radiation Effects on People	32/107
Table (6)	Effects of Overpressure	33/107
Table (7)	Annual Average Temperature, Relative Humidity and Wind Speed / Direction	35/107
Table (8)	Mean of Monthly Air Temperature (°C)	36/107
Table (9)	Mean of Monthly Wind Speed (m/sec)	36/107
Table (10)	Mean of Monthly Morning / Evening Relative Humidity	36/107
Table (11)	Pasqual Stability Categories	39/107
Table (12)	Relationship between Wind Speed and Stability	39/107
Table (13)	Sets of Weather Conditions Initially Selected for this Study	39/107
Table (14)	Dispersion Modeling for Inlet – 1" / 4" Gas release	49/107
Table (15)	Dispersion Modeling for Inlet – 2" / 4" Gas release	52/107
Table (16)	Dispersion Modeling for Inlet – 4" Gas release	56/107

Table (17)	Dispersion Modeling for Outlet – 1” / 10” Gas release	60/107
Table (18)	Dispersion Modeling for Outlet – 4” / 10” Gas release	63/107
Table (19)	Dispersion Modeling for Outlet – 10” Gas release	67/107
Table (20)	Dispersion Modeling for Odorant Tank (Spotleak)	72/107
Table (21)	Dispersion Modeling for Off-take – 1” / 4” Gas release	78/107
Table (22)	Dispersion Modeling for Off-take – 2” / 4” Gas release	81/107
Table (23)	Dispersion Modeling for Off-take – 4” Gas release	84/107
Table (24)	Failure Frequency for Each Scenario	89/107
Table (25)	Off-take 4” / Inlet 4” / Outlet 10” Pipeline Scenarios (Pin Hole Crack – 1” Release) – ETA	92/107
Table (26)	Off-take 4” / Inlet 4” / Outlet 10” Pipeline Scenarios (Half Rupture Release) – ETA	93/107
Table (27)	Off-take 4” / Inlet 4” Pipeline Scenarios (Full Rupture Release) – ETA	94/107
Table (28)	Outlet 10” Pipeline Scenarios (Full Rupture Release) – ETA	95/107
Table (29)	Odorant Tank Release – ETA	96/107
Table (30)	Total Frequencies for Each Scenario	97/107
Table (31)	Summarize the Risk on Workers / Public (Occupancy)	97/107
Table (32)	Individual Risk (IR) Calculation for the Off-Take Public	99/107

Figures		
Figure (1)	Risk Assessment Framework	26/107
Figure (2)	Criteria for Individual Risk Tolerability	28/107
Figure (3)	Proposed Individual Risk Criteria	29/107
Figure (4)	Monthly Variations of the Maximum Temperature for Qena Governorate	36/107
Figure (5)	Monthly Variations of the Wind Speed for Qena Governorate	37/107
Figure (6)	Wind Rose for Qena Governorate	37/107

Figure (7)	Monthly Variations of the Sunny, Cloudy and Precipitation days for Qena Governorate	38/107
Figure (8)	Farshout PRMS and Off-Take Point Plotted on Google Earth Photo	41/107
Figure (9)	Farshout PRMS General Layout (ReGas Data)	42/107
Figure (10)	Farshout Pressure Reduction Station and Surroundings Plotted on Google Earth Photo	43/107
Figure (11)	Farshout Off-Take Point and Surroundings Plotted on Google Earth Photo	44/107
Figure (12)	Gas Cloud Side View (UFL/LFL) (1" hole in 4" Inlet Pipeline)	50/107
Figure (13)	Heat Radiation Contours from Jet Fire (1" hole in 4" Inlet Pipeline)	51/107
Figure (14)	Gas Cloud Side View (UFL/LFL) (2" hole in 4" Inlet Pipeline)	53/107
Figure (15)	Heat Radiation Contours from Jet Fire (2" hole in 4" Inlet Pipeline)	54/107
Figure (16)	Late Explosion Overpressure Waves (2" hole in 4" Inlet Pipeline)	55/107
Figure (17)	Gas Cloud Side View (UFL/LFL) (4" Inlet Pipeline Full Rupture)	57/107
Figure (18)	Heat Radiation Contours from Jet Fire (4" Inlet Pipeline Full Rupture)	58/107
Figure (19)	Late Explosion Overpressure Waves (4" Inlet Pipeline Full Rupture)	59/107
Figure (20)	Gas Cloud Side View (UFL/LFL) (1" hole in 10" Outlet Pipeline)	61/107
Figure (21)	Heat Radiation Contours from Jet Fire (1" hole in 10" Outlet Pipeline)	62/107
Figure (22)	Gas Cloud Side View (UFL/LFL) (4" hole in 10" Outlet Pipeline)	64/107
Figure (23)	Heat Radiation Contours from Jet Fire (4" hole in 10" Outlet Pipeline)	65/107
Figure (24)	Early Explosion Overpressure Waves (4" hole in 10" Outlet Pipeline)	66/107



Figure (25)	Gas Cloud Side View (UFL/LFL) (10" Outlet Pipeline Full Rupture)	68/107
Figure (26)	Heat Radiation Contours from Jet Fire (10" Outlet Pipeline Full Rupture)	69/107
Figure (27)	Early Explosion Overpressure Waves (10" Outlet Pipeline Full Rupture)	70/107
Figure (28)	Heat Radiation Contours from Fireball (10" Outlet Pipeline Full Rupture)	71/107
Figure (29)	Vapor Cloud (UFL/LFL) Side View Graph (Odorant leak)	73/107
Figure (30)	Heat Radiation Contours - Jet Fire Graph (Odorant Leak)	74/107
Figure (31)	Heat Radiation Contours - Jet Fire on Site (Odorant Leak)	
Figure (32)	Late Explosion Overpressure Waves Graph (Odorant Leak)	76/107
Figure (33)	Late Explosion Overpressure Waves on Site (Odorant Leak)	
Figure (34)	Gas Cloud Side View (UFL/LFL) (1" hole in 4" Off-take Pipeline)	79/107
Figure (35)	Heat Radiation Contours from Jet Fire (1" hole in 4" Off-take Pipeline)	80/107
Figure (36)	Gas Cloud Side View (UFL/LFL) (2" hole in 4" Off-take Pipeline)	82/107
Figure (37)	Heat Radiation Contours from Jet Fire (2" hole in 4" off-take Pipeline)	83/107
Figure (38)	Gas Cloud Side View (UFL/LFL) (4" off-take Pipeline Full Rupture)	85/107
Figure (39)	Heat Radiation Contours from Jet Fire (4" off-take Pipeline Full Rupture)	86/107
Figure (40)	Evaluation of Individual Risk	100/107



Executive Summary

This report summarizes the Quantitative Risk Assessment (QRA) analysis study undertaken for the New Natural Gas Pressure Reduction & Metering Station "PRMS" with Odorant at Farshout City – Qena Governorate – Egypt. The PRMS owned by The Egyptian Natural Gas Holding Company "EGAS" and operated by Regional Gas Company "ReGas".

The scope of work includes performing frequency assessment, consequence modeling analysis and Quantitative Risk Assessment of Farshout PRMS in order to assess its impacts on the surroundings.

The main objective of the Quantitative Risk Assessment (QRA) study is to demonstrate that Individual Risk "IR" for workers and for public fall within the ALARP region of Risk Acceptance Criteria, and the new Farshout PRMS does not lead to any unacceptable risks to workers or the public.

QRA Study has been undertaken in accordance with the methodology outlined in the UKHSE as well as international regulations and standards.

QRA starts by Hazard Identification (HAZID) study, which determines the Major Accident Hazards (MAH) that requires consequence modelling, frequency analysis, and risk calculation.

In order to perform consequence-modelling analysis of the potential hazardous scenarios resulting from loss of containment, some assumptions and design basis have been proposed. Three scenarios of the release have been proposed:

1. Gas Release from the inlet / outlet pipeline.
2. Gas Release from the off-take point.
3. Leak from odorant tank.

The QRA has been performed using DNV Phast software (Ver. 7.21) for consequence modelling of different types of hazardous consequences.

Weather conditions have been selected based on wind speed and stability class for the area detailed weather statistics.

The worst case weather conditions has been selected represented by wind speed of 3.14 m/s and stability class "D" representing "Neutral" weather conditions, in order to obtain conservative results. The prevailing wind direction is North West (NW) & West North West (WNW).



As per results from modeling the consequences of each scenario, the following table summarize the study, and as follows:

Event	Scenario	Effects
Pin hole (1") gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will be limited inside the PRMS boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value of 1.6 & 4 kW/m² will be limited inside the PRMS boundary. The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software due to small amount of the gas released.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
Half Rupture (2") gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud (50 % LFL) will extend outside the PRMS from the east side downwind with no effects.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the values of 9.5, 12.5 & 25 kW/m² will extend outside the PRMS southeast fence downwind with no effects inside or outside.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS facilities with some extension outside. The values of 0.137 and 0.206 bar will extend outside the PRMS southeast fence with no effects.</i>



Event	Scenario	Effects
Full Rupture gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects (LFL & 50 % LFL) will extend to reach the SE boundary downwind.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that all heat radiation values will extend outside the PRMS from southeast side with no effects inside.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020, 0.137 & 0.206 bar will extend outside the PRMS boundary from southeast side with no effects.</i>
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	N/D
Pin hole (1") gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud will be limited inside the PRMS boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value 1.6, 4 & 9.5 kW/m² effects will be limited inside the PRMS boundary downwind with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D



Event	Scenario	Effects
Half Rupture (4") gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud (UFL, LFL & 50% LFL) will extend outside the PRMS southeast fence with no effects.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation values of 9.5, 12.5, 25 & 37.5 kW/m² will extend outside the PRMS southeast fence with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside. The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.</i>
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>N/D</i>
Full Rupture gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will extend outside the PRMS southeast fence downwind.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that all radiation values will extend outside the PRMS boundary form southeast side with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside. The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.</i>



Event	Scenario	Effects
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation values of 9.5 & 12.5 kW/m² will be limited inside the PRMS boundary effecting the PRMS facilities.</i>
Odorant tank 1" leak		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the vapor cloud will be limited inside the PRMS boundary and expanded around the PRMS facilities (heavier than air). Consideration should be taken when deal with liquid, vapors and smokes according to the MSDS for the material.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation will be limited inside the PRMS boundary effecting the facilities and near to the firefighting facilities crosswind.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that all values will extend outside the PRMS boundary from the southeast side downwind with no effects.</i>
Pin hole (1") gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will be limited inside the off-take boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value of 1.6 kW/m² will be limited inside the off-take boundary with some extension outside downwind with no effects. The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software as it is very small values.</i>



Event	Scenario	Effects
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
Half Rupture (2") gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will be limited inside the off-take boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value of 1.6 will extend outside the off-take boundary from south, east and west sides with a few meters. The modeling shows that the heat radiation value of & 4 kW/m² will extend outside the off-take boundary downwind with no effects. The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software as it is very small values.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
Full Rupture gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud will be limited inside the off-take boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation values will extend outside the off-take boundary from southeast side downwind with no effects.</i>

Event	Scenario	Effects
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	N/D

The previous table shows that there are some of potential hazards with heat radiation (12.5 kW/m²) resulting from jet fire and explosion overpressure waves (0.137 bar) from late explosion events (Described in table 31).

These risks (Jet fire & Explosion overpressure waves) may affects workers at the PRMS (assuming that one person works in maintenance or inspection). In addition, it was noted that there is no effects from off-take point on surrounding area.

Regarding to risk calculations; the risk to Workers found in Acceptable, so there are some points need to be considered to keep the risk tolerability and this will be described in the study recommendations.

The major hazards that extend over site boundary and/or effect on workers / public were used for Risk Calculations.

Event Tree Analysis (ETA) is an analysis technique for identifying and evaluating the sequence of events in a potential accident scenario following the occurrence of an initiating event. ETA utilizes a visual logic tree structure known as an event tree (ET). ETA provides a Probabilistic Risk Assessment (PRA) of the risk associated with each potential outcome. ETA has been used for scenario development.

The following data and assumptions have been considered in the Event tree analysis (ETA):

- Failure frequency data (mainly E&P Forum/OGP),
- Risk reduction factors (if available),
- Ignition probabilities (both immediate and delayed),
- Vulnerability data.



Risks have been assessed for workers / public using International Risk Management Guidelines as a reference.


The resulting risks have been compared with International Risk Acceptance Criteria.

Risk evaluation for Individual Risk "IR" for the major hazards presented in the following table:

Individual Risk (IR) Calculation for the PRMS Workers

Scenario	Event	People	Individual Risk "IR"	Acceptability Criteria
Gas Release from 4"/10" outlet pipeline	Explosion	Outdoor	$2.34E-06$	Acceptable (✓)
Gas Release from 10" outlet pipeline	Fireball	Outdoor	$7.22E-08$	Acceptable (✓)
	Explosion	Outdoor	$1.03E-08$	Acceptable (✓)
Odorant tank 1" leak	Jet Fire	Outdoor	$1.27E-06$	Acceptable (✓)
TOTAL Risk for the Public (Off-Take)			$3.69E-06$	Acceptable (✓)

The following figure show the Individual Risk "IR" for Farshout PRMS and Off-Take point:



Introduction

The Egyptian Natural Gas Holding Company "EGAS" has engaged Petroleum Safety and Environmental Services Company "PETROSAFE" to identify and evaluate hazards generated from the "New Natural Gas Pressure Reduction and Odorant Station – PRMS" at Farshout City – Qena Governorate – Egypt. The PRMS operated by Regional Gas Company "ReGas" in order to advice protective measures for minimizing risk up to acceptable level.

As part of this review, a QRA study conducted for the following objectives:

- Identify hazardous scenarios related to the most critical unexpected event(s).
- Determine the likelihood of the identified scenarios;
- Model the potential consequences of the identified scenarios;
- Determine the Potential risk of fatality resulting from the identified hazardous scenarios.

The proposed study should also identify existing arrangements for the prevention of major accidents and their mitigation. This would involve emergency plan and procedure for dealing with such events.

PETROSAFE selected to carry out this study, as it has the experience in conducting this type of work.

PETROSAFE is also empowered by the Egyptian General Petroleum Corporation "EGPC" to identify and evaluate factors that relate to Occupational Health & Safety and Environmental Protection.



Technical Definitions

ALARP	<i>Stands for "As Low As Reasonably Practicable", and is a term often used in the milieu of safety-critical and safety-involved systems. The ALARP principle is that the residual risk shall be as low as reasonably practicable.</i>
API	<i>American Petroleum Institute.</i>
Confinement	<i>A qualitative or quantitative measure of the enclosure or partial enclosure areas where vapors cloud may be contained.</i>
Congestion	<i>A qualitative or quantitative measure of the physical layout, spacing, and obstructions within a facility that promote development of a vapor cloud explosion.</i>
DNV PHAST	<i>Process Hazard Analysis Software Tool "PHAST" established by Det Norske Veritas "DNV". Phast examines the progress of a potential incident from the initial release to far-field dispersion including modelling of pool spreading and evaporation, and flammable and toxic effects.</i>
E&P Forum	<i>Exploration and Production "E&P" Forum is the international association of oil companies and petroleum industry organizations formed in 1974. It was established to represent its members' interests at the specialized agencies of the United Nations, governmental and other international bodies concerned with regulating the exploration and production of oil and gas.</i>
EGAS	<i>The Egyptian Natural Gas Holding Company.</i>
EGPC	<i>The Egyptian General Petroleum Corporation.</i>
EX	<i>Explosion Proof Type Equipment.</i>
EERA	<i>Escape, Evacuation and Rescue Assessment.</i>
ESD	<i>Emergency Shut Down.</i>
Explosion	<i>Explosion is the delayed ignition of gas in a confined or congested area resulting in high overpressure waves. Once the explosion occurs, it creates a blast wave that has a very steep pressure rise at the wave front and a blast wind that is a</i>



transient flow behind the blast wave. The impact of the blast wave on structure near the explosion known as blast loading. The two important aspects of the blast loading concern are the prediction of the magnitude of the blast and of the pressure loading onto the local structures. Pressure loading predication as result of a blast; resemble a pulse of trapezoidal or triangular shape. They normally have duration of between approximately 40 msec and 400 msec. The time to maximum pressure is typically 20 msec.

Primary damage from an explosion may result from several events:

- 1. Overpressure - the pressure developed between the expanding gas and its surrounding atmosphere.*
- 2. Pulse - the differential pressure across a plant as a pressure wave passes might cause collapse or movement, both positive and negative.*
- 3. Missiles and Shrapnel - are whole or partial items that are thrown by the blast of expanding gases that might cause damage or event escalation. In general, these "missiles" from atmospheric vapor cloud explosions cause minor impacts to process equipment since insufficient energy is available to lift heavy objects and cause major impacts. Small projectile objects are still a hazard to personnel and may cause injuries and fatalities. Impacts from rupture incidents may produce catastrophic results.*

(ETA)
Event Tree
Analysis

Is a forward, bottom up, logical modeling technique for both success and failure that explores responses through a single initiating event and lays a path for assessing probabilities of the outcomes and overall system analysis. This analysis technique used to analyze the effects of functioning or failed systems, given that an event has occurred.

Failure Rate

Is the frequency with which an engineered system or component fails, expressed in failures per unit of time. It is highly used in reliability engineering.

GASCO

The Egyptian Natural Gas Company.

Gas Cloud
Dispersion

Gas cloud air dilution naturally reduces the concentration to below the LEL or no longer considered ignitable (typically defined as 50 % of the LEL).

HSE Policy	<i>Health, Safety and Environmental Policy.</i>
Hazard	<i>An inherent physical or chemical characteristic (flammability, toxicity, corrosively, stored chemical or mechanical energy) or set of conditions that has the potential for causing harm to people, property, or the environment.</i>
(HAZOP) Hazard And Operability Study	<i>Is a structured and systematic examination of a planned or existing process or operation in order to identify and evaluate problems that may represent risks to personnel or equipment, or prevent efficient operation. The HAZOP technique is qualitative, and aims to stimulate the imagination of participants to identify potential hazards and operability problems; structure and completeness given by using guideword prompts.</i>
(HAZID) Hazard Identification Study	<i>Is a tool for hazard identification, used early in a project as soon as process flow diagrams, draft heat and mass balances, and plot layouts are available. Existing site infrastructure, weather, and Geotechnical data also required, these being a source of external hazards.</i>
(HAC) Hazardous Area Classification	<i>When electrical equipment is used in, around, or near an atmosphere that has flammable gases or vapors, flammable liquids, combustible dusts, ignitable fibers or flying's, there is always a possibility or risk that a fire or explosion might occur. Those areas where the possibility or risk of fire or explosion might occur due to an explosive atmosphere and/or mixture is often called a hazardous (or classified) location/area.</i>
(IR) Individual Risk	<i>The risk to a single person inside a particular building. Maximum individual risk is the risk to the most-exposed person and assumes that the person is exposed.</i>
Jet Fire	<i>A jet fire is a pressurized stream of combustible gas or atomized liquid (such as a high-pressure release from a gas pipe or wellhead blowout event) that is burning. If such a release is ignited soon after it occurs, (i.e., within 2 - 3 minutes), the result is an intense jet flame. This jet fire stabilizes to a point that is close to the source of release, until the release stopped. A jet fire is usually a very localized, but very destructive to anything close to it. This is partly because as well as producing thermal radiation, the jet fire causes considerable convective heating in the region</i>



beyond the tip of the flame. The high velocity of the escaping gas entrains air into the gas "jet" causing more efficient combustion to occur than in pool fires.

Consequently, a much higher heat transfer rate occurs to any object immersed in the flame, i.e., over 200 kW/m² (62,500 Bt/sq. ft) for a jet fire than in a pool fire flame. Typically, the first 10% of a jet fire length is conservatively considered un-ignited gas, as a result of the exit velocity causing the flame to lift off the gas point of release. This effect has been measured on hydrocarbon facility flares at 20% of the jet length, but a value of 10% is used to account for the extra turbulence around the edges of a real release point as compared to the smooth gas release from a flare tip. Jet flames have a relatively cool core near the source. The greatest heat flux usually occurs at impingement distances beyond 40% of the flame length, from its source. The greatest heat flux is not necessarily on the directly impinged side.

kW/m²

Kilowatt per square meter – unit for measuring the heat radiation (or heat flux).

LFL / LEL

Lower Flammable Limit / Lower Explosive Limit - The lowest concentration (percentage) of a gas or a vapor in air capable of producing a flash of fire in presence of an ignition source.

MSDS

Material Safety Data Sheet.

mm Hg

A millimeter of mercury is a manometric unit of pressure, formerly defined as the extra pressure generated by a column of mercury one millimeter high.

MEL

Maximum Exposure Limit.

NFPA

National Fire Protection Association.

N

North Direction.

NE

Northern East Direction.

NW

Northern West Direction.

N/D

Not Determined.

Document Title: Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction & Metering Station

N/R	<i>Not Reached.</i>
OGP	<i>Oil and Gas Producers.</i>
ppm	<i>Part Per Million.</i>
PRMS	<i>Pressure Reduction and Metering Station.</i>
P&ID's	<i>Piping and Instrumentation Diagrams.</i>
PETROSAFE	<i>Petroleum Safety and Environmental Services Company.</i>
QRA	<i>Quantitative Risk Assessment Study is a formal and systematic approach to estimating the likelihood and consequences of hazardous events, and expressing the results quantitatively as risk to people, the environment or your business.</i>
ReGas	<i>Regional Gas Company.</i>
Risk	<i>Relates to the probability of exposure to a hazard, which could result in harm to personnel, the environment or public. Risk is a measure of potential for human injury or economic loss in terms of both the incident likelihood and the magnitude of the injury / loss.</i>
Risk Assessment	<i>The identification and analysis, either qualitative or quantitative, of the likelihood and outcome of specific events or scenarios with judgments of probability and consequences.</i>
scm/hr	<i>Standard Cubic Meter Per Hour.</i>
SCBA	<i>Self-Contained Breathing Apparatus.</i>
SE	<i>Southern East Direction.</i>
SW	<i>Southern West Direction.</i>
TWA	<i>Time Weighted Averages.</i>
UFL/UEL	<i>Upper flammable limit, the flammability limit describing the richest flammable mixture of a combustible gas.</i>
UVCE	<i>When a flammable vapor is released, its mixture with air will form a flammable vapor cloud. If ignited, the flame speed may accelerate to high velocities and produce significant blast overpressure.</i>
V	<i>Volume.</i>
Vapor Cloud Explosion (VCE)	<i>An explosion in air of a flammable material cloud.</i>



Objectives

The objectives of this QRA for the unit facilities are:

- Identify hazardous scenarios related to the facilities based on historical data recorded;
- Determine the likelihood (frequencies) of the identified scenarios;
- Model the potential consequences of the identified scenarios;
- Determine the Potential risk of fatality resulting from the identified hazardous scenarios;
- Evaluate the risk against the acceptable risk level to ensure that it is within *As Low As Reasonably Practicable* "ALARP", otherwise additional control measures and recommendations will be provided at this study to reduce the Risk, (ALARP).



Quantitative Risk Assessment Study Scope

The scope of work of this QRA study is limited to the following:

- Identification of the Most Critical Event(s) or scenarios that may lead to fatal accidents as well as to ensure that the expected risk will not exceed the Acceptable Risk Level as per national and international standards;
- To assess and quantify the risks associated with Farshout PRMS and the off-take point on the neighboring / surrounding community;
- The study determines Frequencies, Consequences (Including Associated Effect Contours) and Potential Risk of Fatality for the identified hazardous scenarios;
- Normal operation of the facilities (e.g. Construction and specific maintenance activities) are excluded from this analysis.



Quantitative Risk Assessment "QRA" Studies

Method of Assessment

1.0- General Method Used

Attention mainly focussed on those accidents where a gross failure of containment could result in the generation of a large vapour cloud of flammable or toxic material. The approach adopted has involved the following stages:

- Identification of hazardous materials,
- Establishment of maximum total inventories and location.

During the site visit by the study team, the overall functioning of the site discussed in some detail and the Companies asked to provide a complete list of holdings of hazardous materials. A preliminary survey notes was issued by the team, as a private communication to the company concerned, and this formed the basis for subsequent more discussion and analysis.

From the PRMS design model provided by the client, it was impractical to examine in depth all possible failure modes for all parts within the time allowed for this study. Instead, only those potential failures, which might contribute, either directly or indirectly, to off-site risks were examined.

2.0- Risk Assessment

As the PRMS designed and prepared for construction, so it was therefore necessary for the study team to identify and analyse the hazards potential from first principles the routes by which a single or multiple accident could affect the community or neighbouring.

The terms of reference required the team to investigate and determine the overall risk to health and safety both from individual installations and then foreseeable interactions.

The assessment of risk in a complex situation is difficult. No method is perfect as all have advantages and limitations.

It was agreed that the quantitative approach was the most meaningful way of comparing and evaluating different risks. The risk assessment framework shown in Figure (1) used for the study.




Figure (1) Risk Assessment Framework



Modeling the Consequences

Modeling of the consequences is one of the key steps in Quantitative Risk Assessment "QRA", as it provides the link between hazard identification (in this study Potential Loss of Containment Incidents) and the determination of possible impact of those incidents on People (Worker / Public), Asset and the Environment.

In this study, Natural Gas (Mainly Methane CH₄) was considered. There are several types of consequences to be considered for modelling, these include Gas Dispersion (UFL - LFL - 50 % LFL) / Heat Radiation / Explosion Overpressure modeling, also each of these scenarios described in the following table:

Table (1) Description of Modeling of the Different Scenario

<i>Discharge Modeling</i>	<i>Modeling of the mass release rate and its variation overtime.</i>
<i>Radiation Modeling</i>	<i>Modeling of the Thermal radiation from fires.</i>
<i>Dispersion Modeling</i>	<i>Modeling of the Gas and two-phase releases.</i>
<i>Overpressure</i>	<i>Associated with explosions or pressure burst.</i>

Toxic hazards are considered as result of releases / loss of containment for which discharge modeling and gas dispersion modeling are required. The hazard ranges are dependent upon the condition of the release pressure and rate of release.

There are a number of commercial software for modeling gas dispersion, fire, explosion and toxic releases. PETROSAFE select the DNV PHAST Ver. 7.21 Software package in modeling scenarios.

The software developed by DNV in order to provide a standard and validated set of consequence models that can be used to predict the effects of a release of hydrocarbon or chemical liquid or vapour. (Results of the modeling presented in pages from 49 to 86)



Criterion for Risk Tolerability

The main function of this phase of the work was to assess the effectiveness of the proposed arrangement for managing risks against performance standards.

In order to do this, we need firstly to define a performance standard and secondly, to be able to analyse the effectiveness of the arrangements in a manner which permits a direct comparison with these standards.

The defining of performance standards undertakes at the following three levels:

- Policy-based
- System
- Technical

Where the present work is mainly concerned with the assessment against the standards associated with the first two levels.

The policy-based performance standard relates to this objective to provide a working environment, where the risk to the individual reduced to a level that is ALARP.

This performance standard is therefore, expressed in the form of individual risk and the arrangements for managing this risk should result in a level of 'Individual Risk', based on a proposed Tolerability Criteria, Figure (2).




Figure (2) Criteria for Individual Risk Tolerability



The criterion for IR tolerability for workers and to the public outlined in Table (2) and Figure (3).

It should be noted that this criteria proposed only as a guideline. Risk assessment is no substitute to professional judgement.

Table (2) Proposed Individual Risk (IR) Criteria (per person/year)

Risk Level	Workers	Public
<i>Intolerable</i>	$> 10^{-3}$ per person/yr.	$> 10^{-4}$ per person/yr.
<i>Negligible</i>	$> 10^{-5}$ per person/yr.	$> 10^{-6}$ per person/yr.




Figure (3) Proposed Individual Risk Criteria

Workers would include the Company employees and contractors. The public includes the public, visitors, and any third party who is not directly involved in the Company work activities.

On this basis, we have chosen to set our level of intolerability at Individual Risk for workers of 1 in 1,000 per year, and we define an individual risk of 1 in 100,000 per year as broadly acceptable. Consequently, our ALARP region is between 1 in 1,000 and 1 in 100,000 per person/year.

It is important to ensure that conflict between these subordinate standards and those stemming from international codes and standards are avoided and that any subordinate standards introduced are at least on a par with or augment those standards, which are associated with compliance with these international

requirements. These system level performance standards are included as part of the summaries from the QRA. These used as the basis for assessing the suitability and sufficiency of ReGas Site arrangements for both protecting personnel on site and members of public from major hazards and securing effective response in an emergency. Failure to meet acceptance criteria at this level results in the identification of remedial measures for assessment both qualitatively and quantitatively.

The analytical work use a system analysis approach and divided into a number of distinct phases:

- Data collection, including results from site-based qualitative assessments.
- Definition of arrangements.
- Qualitative evaluation of arrangements against a catalogue of fire and explosion hazards from other major accident hazards.
- Preparing of event tree analysis models.
- Consolidation of list of design events.
- Analysis of the effect of design events on fire, explosion and toxic hazard management and emergency response arrangements.
- Quantification of that impact in terms of individual risk.

The main model would base on a systems approach, and it takes the following form:

- Estimates of incremental individual risk (IIR) per person/yr.
- Is caused-consequences based.
- Uses event tree analysis to calculate the frequency of occurrence.
- Estimates incremental individual risk utilizing event tree analysis, based on modeling the emergency response arrangements from detection through to recovery to a place of safety.



Personnel Vulnerability and Structural Damage

A criterion used in the QRA study for the calculation of personnel vulnerability and structural / asset damage because of fire, explosion and toxic release shown in Table (3).

The criteria shown below provide some assumptions for the impairment effects of hydrocarbon releases on personnel and structures, which based on Health and Safety Executive: Methods of approximation and determination of human vulnerability for offshore major accident hazard assessment.

Table (3) Criteria for Personnel Vulnerability and Structural Damage

Event Type	Threshold of Fatality	Asset/Structural Damage
Jet and Diffusive Fire Impingement	6.3 kW/ m ² (1)	- Flame impingement 10 minutes.
	12.5 kW/m ² (2)	- 300- 500 kW/m ² Structural Failure within 20 minutes.
Pool Fire Impingement	6.3 kW/ m ² (1)	- Flame impingement 20 minutes
	12.5 kW/m ² (2)	- 100 - 150 kW/m ² Structural Failure within 30 minutes.
Smoke	2.3% v/v (3)	
	15% v/v (4)	
Explosion Overpressure	300 mbar	100 mbar

- (1) Fatality within 1 - 2 minutes
- (2) Fatal < 1 minute
- (3) Above 2.3%, escape possible but difficult
- (4) No escape possible, fatal in a few seconds

The effects of exposure to fire expressed in terms of heat radiation (kW/m²) and overpressure waves shown in Tables (4), (5) and (6).



Table (4) Heat Radiation Effects on Structures (World Bank)

Radiation Level kW/m ²	Observed Effect
37.5	Sufficient to cause damage to process equipment.
25	Minimum energy to ignite wood at indefinitely long exposure (non-piloted).
12.5	Minimum energy required to ignite wood, melting of plastic tubing.

Table (5) Heat Radiation Effects on People

Radiation Level kW/m ²	Effects on People
1.2	Equivalent to heat from sun at midday summer.
1.6	Minimum level at which pain can be sensed.
4 - 6	Pain caused in 15 - 20 seconds, Second Degree burns after 30 seconds.
12	20 % chance of fatality for 60 seconds exposure.
25	100 % chance of fatality for continuous exposure. 50 % chance of fatality for 30 seconds exposure.
40	30 % chance of fatality for 15 seconds exposure.
50	100 % chance of fatality for 20 seconds exposure.

*Table (6) Effects of Overpressure*

Pressure		Effects / Damage
bar	psig	
0.002	0.03	Occasional breakage of glass windows.
0.006	0.1	Breakage of some small windows.
0.021	0.3	Probability of serious damage beyond this point = 0.05. 10 % glass broken.
0.027	0.4	Minor structural damage of buildings.
0.068	1.0	Partial collapse of walls and roofs, possible injuries.
0.137	2.0	Some severe injuries, death unlikely.
0.206	3.0	Steel frame buildings distorted / pulled from foundation.
0.275	4.0	Oil storage tanks ruptured.
0.344	5.0	Wooden utilities poles snapped / Fatalities.
0.41	6.0	Nearly complete destruction of building.
0.48	7.0	Loaded wagon train overturned.
0.689	10.0	Total destruction of buildings.

Quantification of the Frequency of Occurrence

The probability of a sequence of events leading to a major hazard is dependent on the probability of each event in a sequence occurring; usually these probabilities may be multiplied together to obtain the end event probability or frequency.

The technique of Quantified Risk Assessment 'QRA' requires data in the form of probability or frequency to be estimated for each input event.

Ideally, data relating to hardware failures and human error that are specific to each plant should be obtained from the company's maintenance and historical records.

Unfortunately, records available were not in the form that allows data relevant to this study to be obtained. Therefore, other sources of data were used as a basis for failure/error scenarios. The sources of information and data are shown in the References section of this report.

Identification of Scenarios Leading to Selected Failures

For each selected failure scenario, the potential contributory factors were examined, taking into account any protective features available. Typically, the factors examined included:

- Operator error
- Metallurgical fatigue or ageing of materials
- Internal or external Corrosion
- Loss of process control, e.g. pressure, temperature or flow, etc.
- Overfilling of vessels
- Introduction of impurities
- Fire and/or explosion
- Missiles
- Flooding

Account was taken at this stage of those limited releases, which, although in themselves did not constitute a significant off-site hazard could, under some circumstances, initiate a sequence leading to a larger release, as a knock-on effect.

It was noted that the proposed criterion for risk tolerability was used in Egypt by the following organizations: British Gas / British Petroleum / Shell / Total.



Relevant Weather Data for the Study

- Weather Data

The Weather Data relevant to this study consists of a list of weather conditions in the form of different combinations of wind-speed/direction, temperature, humidity and atmospheric stability. Table (7)

The weather conditions are an important input into the dispersion calculations and results for a single set of conditions could give a misleading picture of the hazard potential.

Met-oceanographic data gathered from Weather base for Qena Governorate over a period of some years.

These data included wind speed, wind direction, air temperature and humidity, as well as current speed, direction and wave height.

Table (7) Annual Average Temperature, Relative Humidity and Wind Speed / Direction

• Air Temperature °C		
	Min. Recorded	14.5 °C
	Max. Recorded	31.8 °C
	<i>Annual Average</i>	<i>24.3 °C</i>
• Relative Humidity %		
	Average Daily Min.	27.6 %
	Average Daily Max.	53.9 %
	<i>Annual Average</i>	<i>40 %</i>
• Wind Speed m/s		
	<i>Annual Average</i>	<i>3.14 m / sec.</i>
• Wind Direction		
	<i>Annual Average</i>	<i>NW / WNW</i>

The general climatic conditions at Qena Governorate are summarized in Tables No. (8, 9 & 10) Below.



Table (8) Mean of Monthly Air Temperature (°C)

Months	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Temp. (c°)	14.5	16.3	20.1	25.1	29.3	31.7	31.8	31.1	29.2	26.1	20.6	16.1

Table (9) Mean of Monthly Wind Speed (m/sec)

Months	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind Speed (m/sec)	3.31	3.39	3.5	3.69	3.61	3.61	3.5	3.39	3.50	2.19	2.11	2

Table (10) Mean of Monthly Average Relative Humidity

Months	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Relative Humidity (%)	53.5	46.1	39.1	32	27.6	28.5	32.8	36.6	39.6	41.5	49	53.9

Figure (4) shows the maximum temperature diagram for Qena Governorate




Figure (4) – Monthly Variations of the Maximum Temperature – Qena Governorate



Figures (5 & 6) show the monthly variations of the wind speed as well as wind rose for Qena Governorate respectively.




Figure (5) – Monthly Variations of the Wind Speed – Qena Governorate




Figure (6) – Wind Rose – Qena Governorate



Figure (7) shows the monthly variations of the sunny, cloudy and precipitation days for Qena Governorate.




Figure (7) – Monthly Variations of the Sunny, Cloudy and Precipitation days for Qena Governorate



- Stability Categories

The two most significant variables, which would affect the dispersion calculations, are Wind-speed and atmospheric stability. The stability class is a measure of the atmospheric turbulence caused by thermal gradients. Pasqual Stability identifies six main categories, which shown in the Tables (11 & 12) and summarized in Table (13).

Table (11) Pasqual Stability Categories

A	B	C	D	E	F
Very Unstable	Unstable	Moderately Unstable	Neutral	Moderately Stable	Stable

Neutral conditions correspond to a vertical temperature gradient of about 1°C per 100 m.

Table (12) Relationship between Wind Speed and Stability

Wind speed (m/s)	Day-time Solar Radiation			Night-time Cloud Cover		
	Strong	Medium	Slight	Thin <3/8	Medium >3/8	Overcast >4/5
<2	A	A-B	B	-	-	D
2-3	A-B	B	C	E	F	D
3-5	B	B-C	C	D	E	D
5-6	C	C-D	D	D	D	D
>6	C	D	D	D	D	D

Table (13) Sets of Weather Conditions Initially Selected for this Study

Set for Wind Speed and Stability	
Wind speed	Stability
3.14 m/sec.	D



Farshout PRMS Description

Background

Farshout Pressure Reduction and Metering Station Operated by Region Gas Company "ReGas". It is located about 7 km Southwest direction from Farshout City downtown. The PRMS will provide the natural gas to Farshout area public housing.

The PRMS feeding will be from the National Gas Pipeline owned by GASCO by off-take point at a distance of about 3 km from the PRMS premises. The off-take point pressure will be from 45 to 70 bar, then the pressure reduced to 4 - 7 bar at the PRMS facilities with adding odorant, and then connected to the internal distribution network to public housing at Farshout area and surrounding villages.

The PRMS & Off-Take Point Location Coordinates (ReGas Data)

Point	PRMS		Off-take Point	
	North (N)	East (E)	North (N)	East (E)
1	26° 00' 31.26"	32° 07' 08.84"	25° 59' 43.14"	32° 08' 44.74"
2	26° 00' 31.12"	32° 07' 10.17"		
3	26° 00' 29.70"	32° 07' 09.30"		
4	26° 00' 30.47"	32° 07' 07.72"		

PRMS Brief Description and Components (ReGas Data)

The PRMS will be surrounded by 3 m height fence and mainly consist of the followings: (Ref. Figures 8, 9, 10 and 11)

- Inlet module: which contains 4" # 600 manual isolation valve.
- Filter module: two identical streams each contain inlet and outlet isolation valves.
- Heating system module: two identical.
- Metering module: two identical.
- Regulating module: two identical regulating lines.
- Outlet module: it contains manual outlet isolation valve.
- Odorant module: 25 lit. capacity container.
- Off-take point will be from up-ground room surrounded by 3 m height brick wall fence containing connection pipes and isolation valves with GASCO underground pipeline 4", connected to 4" PRMS feeding pipeline.
- Security Office (one floor)
- Administration office (one floor)
- Firefighting Facilities (Fire Water Tank / Pumps / Fire water Network)




Figure (8) Farshout PRMS and Off-Take Point Plotted on Google Earth Photo




Figure (10) Farshout Pressure Reduction Station and Surroundings Plotted on Google Earth Photo




Figure (11) Farshout Off-Take Point and Surroundings Plotted on Google Earth Photo



Pressure Reduction and Metering Station (PRMS)

Consists of equipment installed for automatically reducing and regulating the pressure in the downstream pipeline or main to which it is connected. Included are piping and auxiliary devices such as valves, control instruments, control lines, the enclosure, and ventilation equipment.

PRMS required for Farshout city having an inlet pressure range (22-45 barg) and outlet pressure 7 bar g and maximum flow rate 5000 SCM/H.

Pressure Reduction Station Mechanical Works

Constructing Pressure Reduction Stations and city gate regulators are regular construction works in addition to connections between transmission mains and distribution mains.

The PRMS comprises two types of pressures; the first is the upstream pressure, which a high pressure is ranging from 22 to 45 Bar, while the second pressure is the downstream pressure, which is a low-pressure (7 bar) Inlet stage.

The inlet components of the PRMS should be completely isolated from the cathodic system applied to the feeding steel pipes. This is achieved by installing isolating joint with protection.

Filtration Stage

The aim of the filtration stage is to remove dust, rust, solid contaminants and liquid traces. Two filters and two separators are installed in parallel; each filter-separator operates with the full capacity of the PRMS. Filter-separator lines are equipped with safety devices such as differential pressure gauges, relief valves, liquid indicators, etc.

Heating Stage

Because the difference between the inlet and outlet pressure is relatively high, icing normally occurs around outlet pipes. This may cause blockings and accordingly reduce or stop the gas flow. To avoid such circumstances, a heater is installed to keep the temperature of outlet pipes over 7 °C. Each PRMS is equipped with two heaters in parallel in order to allow for a standby heater in emergencies.

Reduction Stage

Each PRMS includes two reduction lines in parallel, also to allow for a standby line. The lines are equipped with safety gauges, indicators and transmitters to maintain safe operation conditions. According to the IGM standards, the reduction unit should be installed in a well-ventilated-closed area or, alternatively, in an open protected area.



- Flash Point	-17.8° C
- Freezing Point	-45.5° C
- Density (H ₂ O = 1)	0.812 @ 15.5° C
- Vapor Density	3.0 (air = 1)
- Vapor Pressure (mm Hg)	6.6 @ 37.8° C

Health Hazards

Spotleak is not carcinogenic, but the major health hazards as a result of exposure to Spotleak include the following:

Inhalation

- Short-term exposure: Irritation and central nervous system effects
- Long-term exposure: Irritation

Skin Contact

- Short-term: Irritation
- Long-term: Dermatitis

Eye Contact

- Short-term: Irritation and tearing
- Long-term: Irritation

Ingestion

- Short-term: nausea, vomiting, central nervous system effects
- Long-term: no effects are known

Hygiene Standards and Limits

Occupational Exposure Limit for Spotleak to all components is 45 ppm, and the long-term "MEL" should be below 12 ppm (8 hrs. "TWA").

Fire and Explosion Hazards

Spotleak is a severe fire hazard. Vapor/air mixtures are explosive. Vapor is 3 times heavier than air. Vapor may ignite at distant ignition sources and flash back.

Thermal decomposition products include oxides of sulphur and hydrogen sulphide.



Fire Fighting and Protection Systems and Facilities

As per agreement with EGAS and Civil Defense, the PRS will be provided by the following fire protection facilities:

- Smoke detector in all admin rooms.
- Heat detectors in buffet rooms.
- Smoke detectors in control rooms according to the area.
- Different sizes of fire extinguishers will be distributed at PRS site.

Additional firefighting facilities may be installed at the PRS, where a 40 ton water tank will be available feeding 4 inch firefighting network, using three firefighting pumps (one electric pump 250 gpm @ 8 bar – one diesel pump 250 gpm @ 8 bar – one jockey pump 30 gpm @ 8 bar).

Emergency Response Plan "ERP"

An Emergency Response Plan "ERP" for Farshout PRS should be prepared by REGAS; during Construction phase, and planned to include the following items:

- ERP objectives,
- Emergency levels,
- Notification Chart,
- Main Emergency Room Members Contacts,
- REGAS Branches Contacts,
- Calling of External Aids / Authorities at Farshout Area,
- Roles & Responsibilities,
 - Area Security Manager Responsibilities;
 - Firefighting Team Responsibilities;
 - Rescue & Evacuation Responsibilities;
 - Document Control Team Responsibilities;
 - First Aid Team Responsibilities;
 - Power Shutdown Team Responsibilities;
 - Communications Team Responsibilities;
- Emergency Procedures in case of Potential Risks.



Analytical Results of Consequence Modeling

1.0- Pressure Reduction Station Inlet Pipeline (4 inch)

1/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release

The following table no. (14) Show that:

Table (14) Dispersion Modeling for Inlet - 1" / 4" Gas Release

Gas Release (Inlet / PRV "High Pressure")				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	0.90	1.04	0.08 @ 0.50 m
	LFL	3.34	1.16	0.32 @ 2.00 m
	50 % LFL	5.55	0 – 1.32	1.32 @ 3.50 m

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	5.64	1.6	7	3.66	0
		4	4.32	1.68	0
		9.5	Not Reached	Not Reached	0
		12.5	Not Reached	Not Reached	20% /60 sec.
		25	Not Reached	Not Reached	80.34
		37.5	Not Reached	Not Reached	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	N/D	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	N/D	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	N/D	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>




Figure (12) Gas Cloud Side View (UFL/LFL) (1" hole in 4" Inlet Pipeline)

- The previous figure shows that if there is a gas release from 1" hole size without ignition the flammable vapors will reach a distance more than 5.50 m downwind and from 0 – 1.32 m height.
- The UFL will reach a distance of about 0.90 m downwind with a height of 1.04 m. The cloud large width will be 0.08 m crosswind at a distance of 0.50 m from the source.
- The LFL will reach a distance of about 3.34 m downwind with a height of 1.16 m. The cloud large width will be 0.32 m crosswind at a distance of 2 m from the source.
- The 50 % LFL will reach a distance of about 5.55 m downwind with a height from 0 to 1.32 m. The cloud large width will be 1.32 m crosswind at a distance of 3.50 m from the source.

The modeling shows that the gas cloud effects will be limited inside the PRMS boundary.




Figure (13) Heat Radiation Contours from Jet Fire (1" hole in 4" Inlet Pipeline)

- The previous figure show that if there is a gas release from 1" hole size and ignited the expected flame length is about 5.64 meters downwind.
- The 1.6 kW/m^2 heat radiation contours extend about 7 meters downwind and 3.66 meters crosswind.
- The 4 kW/m^2 heat radiation contours extend about 4.32 meters downwind and 1.68 meters crosswind.
- The 9.5 kW/m^2 heat radiation not reached.
- The 12.5 kW/m^2 heat radiation not reached.
- The 25 kW/m^2 heat radiation not reached.
- The 37.5 kW/m^2 heat radiation not reached.

The modeling shows that the heat radiation value of 1.6 & 4 kW/m^2 will be limited inside the PRMS boundary. The values of 9.5 , 12.5 , 25 & 37.5 kW/m^2 not determined by the software due to small amount of the gas released.



1/2- Consequence Modeling for 2 inch (Half Rup.) Gas Release

The following table no. (15) Show that:

Table (15) Dispersion Modeling for Inlet - 2" / 4" Gas Release

Gas Release				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	1.90	1.10	0.20 @ 1.00 m
	LFL	7	1.35	0.70 @ 4.00 m
	50 % LFL	14.20	0 – 1.70	1.40 @ 8.00 m

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	11.43	1.6	17.40	11.75	0
		4	13.40	7.20	0
		9.5	10.30	3.84	0
		12.5	9	2.90	20% /60 sec.
		25	3.20	0.40	80.34
		37.5	Not Reached	Not Reached	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	24	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	13	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	12	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>




Figure (14) Gas Cloud Side View (UFL/LFL) (2" hole in 4" Inlet Pipeline)

- The previous figure shows that if there is a gas release from 2" hole size without ignition the flammable vapors will reach a distance about 14 m downwind and from 0 to 1.70 m height.
- The UFL will reach a distance of about 1.90 m downwind with a height of 1.10 m. The cloud large width will be 0.20 m crosswind at a distance of 1 m from the source.
- The LFL will reach a distance of about 7 m downwind with a height of 1.35 m. The cloud large width will be 0.70 m crosswind at a distance of 4 m from the source.
- The 50 % LFL will reach a distance of about 14.20 m downwind with a height from 0 to 1.70 m. The cloud large width will be 1.40 m crosswind at a distance of 8 m from the source.

The modeling shows that the gas cloud (50 % LFL) will extend outside the PRMS from the east side downwind with no effects.




Figure (15) Heat Radiation Contours from Jet Fire (2" hole in 4" Inlet Pipeline)

- The previous figure shows that if there is a gas release from 2" hole size and ignited the expected flame length is about 11.43 meters downwind.
- The 9.5 kW/m² heat radiation contours extend about 10.30 meters downwind and 3.84 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 9 meters downwind and 2.90 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 3.20 meters downwind and 0.40 meters crosswind.
- The 37.5 kW/m² heat radiation not determined.

The modeling shows that the values of 9.5, 12.5 & 25 kW/m² will extend outside the PRMS southeast fence downwind with no effects inside or outside.




Figure (16) Late Explosion Overpressure Waves (2" hole in 4" Inlet Pipeline)

- The previous figure shows that if there is a gas release from 2" hole size and late ignited this will give an explosion with different values of overpressure waves.
- The 0.020 bar overpressure waves will extend about 24 meters downwind.
- The 0.137 bar overpressure waves will extend about 13 meters downwind.
- The 0.206 bar overpressure waves will extend about 12 meters downwind.

The modeling shows that the value of 0.020 bar will cover the PRMS facilities with some extension outside.

The values of 0.137 and 0.206 bar will extend outside the PRMS southeast fence with no effects.



1/3- Consequence Modeling for 4 inch (Full Rupture) Gas Release

The following table no. (16) Show that:

Table (16) Dispersion Modeling for Inlet - 4" Gas Release

Gas Release					
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)	
3.14 D	UFL	4.20	1.20	0.40 @ 2.50 m	
	LFL	18.50	1.80	1.60 @ 10.50 m	
	50 % LFL	43	0 – 2.85	2.85 @ 24.50 m	
Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	23.61	1.6	35.40	24.50	0
		4	27.20	15.30	0
		9.5	21.20	8.90	0
		12.5	19.20	7.10	20 %/60 sec.
		25	15.40	3.12	80.34
		37.5	8.40	2.80	98.74
Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	73	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	48	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	46	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>
Fireball					
Wind Category	Heat Radiation (kW/m ²)	Distance (m)	Heat Radiation (kW/m ²) Effects on People & Structures		
3.14 D	1.6	Not Determined	12.5	<i>20 % Chance of fatality for 60 sec exposure</i>	
	4	Not Determined	25		
	9.5	Not Determined		<i>100 % Chance of fatality for continuous exposure</i>	
	12.5	Not Determined			
	25	Not Determined		<i>50 % Chance of fatality for 30 sec exposure</i>	
	37.5	Not Determined	37.5		




Figure (17) Gas Cloud Side View (UFL/LFL) (4" Inlet Pipeline Full Rupture)

- The previous figure shows that if there is a gas release from 4" pipeline full rupture without ignition, the flammable vapors will reach a distance more than 43 m downwind and over 2 m height.
- The UFL will reach a distance of about 4.20 m downwind with a height of 1.20 m. The cloud large width will be 0.40 m crosswind at a distance of 2.50 m from the source.
- The LFL will reach a distance of about 18.50 m downwind with a height of 1.80 m. The cloud large width will be 1.60 m crosswind at a distance of 10.50 m from the source.
- The 50 % LFL will reach a distance of about 43 m downwind with a height from 0 to 2.85 m. The large width will be 2.85 m crosswind at a distance of 24.50 m from the source.

The modeling shows that the gas cloud effects (LFL & 50 % LFL) will extend to reach the SE boundary downwind.




Figure (18) Heat Radiation Contours from Jet Fire (4" Inlet Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 4" pipeline full rupture and ignited the expected flame length is about 23 meters downwind.
- The 9.5 kW/m² heat radiation contours extend about 21.20 meters downwind and 8.90 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 19.20 meters downwind and 7.10 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 15.40 meters downwind and 3.12 meters crosswind.
- The 37.5 kW/m² heat radiation contours extend about 8.40 meters downwind and 2.80 meters.

The modeling shows that all heat radiation values will extend outside the PRMS from southeast side with no effects inside.




Figure (19) Late Explosion Overpressure Waves (4" Inlet Pipeline Full Rupture)

- The previous figure shows that if there is gas release from 4" pipeline full rupture and late ignited this will give an explosion with different values of overpressure waves.
- The 0.020 bar overpressure waves will extend about 73 meters downwind.
- The 0.137 bar overpressure waves will extend about 48 meters downwind.
- The 0.206 bar overpressure waves will extend about 46 meters downwind.

The modeling shows that the value of 0.020, 0.137 & 0.206 bar will extend outside the PRMS boundary from southeast side with no effects.



2.0- Pressure Reduction Station Outlet Pipeline (10 inch)

2/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release

The following table no. (17) Show that:

Table (17) Dispersion Modeling for Outlet - 1" / 10" Gas Release

Gas Release (Outlet / PRV "Low Pressure")				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	1.02	1.05	0.10 @ 0.60 m
	LFL	3.90	1.19	0.38 @ 2.50 m
	50 % LFL	6.68	0 – 1.37	1.37 @ 4.50 m

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	6.48	1.6	8.40	4.90	0
		4	5.80	2.60	0
		9.5	2.60	0.72	0
		12.5	Not Reached	Not Reached	20% /60 sec.
		25	Not Reached	Not Reached	80.34
		37.5	Not Reached	Not Reached	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	N/D	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	N/D	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	N/D	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>




Figure (20) Gas Cloud Side View (UFL/LFL) (1" hole in 10" Outlet Pipeline)

- The previous figure show that if there is a gas release from 1" hole size without ignition the flammable vapors will reach a distance more than 6 m downwind and over 1.37 m height.
- The UFL will reach a distance of about 1.02 m downwind with a height of 1.05 m. The cloud large width will be 0.10 m crosswind at a distance of 0.60 m from the source.
- The LFL will reach a distance of about 3.90 m downwind with a height of 1.19 m. The cloud large width will be 0.38 m crosswind at a distance of 2.50 m from the source.
- The 50 % LFL will reach a distance of about 6.68 m downwind with a height of from 0 to 1.37 m. The cloud large width will be 1.76 m crosswind at a distance of 7 m from the source.

The modeling shows that the gas cloud will be limited inside the PRMS boundary.




Figure (21) Heat Radiation Contours from Jet Fire (1" hole in 10" Outlet Pipeline)

- The previous figure shows that if there is a gas release from 1" hole size and ignited the expected flame length is about 6.48 meters downwind.
- The 1.6 kW/m² heat radiation contours extend about 8.40 meters downwind and 4.90 meters crosswind.
- The 4 kW/m² heat radiation contours extend about 5.80 meters downwind and 2.60 meters crosswind.
- The 9.5 kW/m² heat radiation contours extend about 2.60 meters downwind and 0.72 meters crosswind.
- The 12.5 kW/m² heat radiation not reached.
- The 25 kW/m² heat radiation not reached.
- The 37.5 kW/m² heat radiation not reached.

The modeling shows that the heat radiation value 1.6, 4 & 9.5 kW/m² effects will be limited inside the PRMS boundary downwind with no effects.



2/2- Consequence Modeling for 4 inch (Half Rup.) Gas Release

The following table no. (18) Show that:

Table (18) Dispersion Modeling for Outlet - 4" / 10" Gas Release

Gas Release				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	5.50	1	0.30 @ 1.00 m
	LFL	25.28	0 – 2.20	2.20 @ 17.00 m
	50 % LFL	25.51	0 – 3.25	3.10 @ 25.50 m

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	29.64	1.6	51	34.30	0
		4	37.80	21.50	0
		9.5	29.40	12.60	0
		12.5	26.70	10.20	20% /60 sec.
		25	21.60	4.75	80.34
		37.5	12.80	2.36	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)

Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	64	N/D	0.021 bar	Probability of serious damage beyond this point = 0.05 - 10 % glass broken
	0.137	16	N/D	0.137 bar	Some severe injuries, death unlikely
	0.206	12	N/D	0.206 bar	Steel frame buildings distorted / pulled from foundation




Figure (22) Gas Cloud Side View (UFL/LFL) (4" hole in 10" Outlet Pipeline)

- The previous figure shows that if there is a gas release from 4" hole size without ignition the flammable vapors will reach a distance more than 25 m downwind and 3.25 m height.
- The UFL will reach a distance of about 5.50 m downwind with a height of 1 m. The cloud large width will be 0.30 m crosswind at a distance of 1 m from the source.
- The LFL will reach a distance of about 25.28 m downwind with a height from 0 to 2.20 m. The cloud large width will be 2.20 m crosswind at a distance of 17 m from the source.
- The 50 % LFL will reach a distance of about 25.51 m downwind with a height from 0 to 3.25 m. The cloud large width will be 3.10 m crosswind at a distance of 25.50 m from the source.

The modeling shows that the gas cloud (UFL, LFL & 50% LFL) will extend outside the PRMS southeast fence with no effects.




Figure (23) Heat Radiation Contours from Jet Fire (4" hole in 10" Outlet Pipeline)

- The previous figure shows that if there is a gas release from 4" hole size and ignited the expected flame length is about 29.64 meters downwind.
- The 9.5 kW/m² heat radiation contours extend about 29.40 meters downwind and 12.60 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 26.70 meters downwind and 10.20 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 21.60 meters downwind and 4.75 meters crosswind.
- The 37.5 kW/m² heat radiation contours extend about 12.80 meters downwind and 2.36 meters crosswind.

The modeling shows that the heat radiation values of 9.5, 12.5, 25 & 37.5 kW/m² will extend outside the PRMS southeast fence with no effects.




Figure (24) Early Explosion Overpressure Waves (4" hole in 10" Outlet Pipeline)

- The previous figure show that if there is a gas release from 4" hole size and early ignited this will give an explosion with different values of overpressure waves.
- The 0.020 bar overpressure waves will extend about 64 meters radius.
- The 0.137 bar overpressure waves will extend about 16 meters radius.
- The 0.206 bar overpressure waves will extend about 12 meters radius.

The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside.

The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.



2/3- Consequence Modeling for 10 inch (Full Rup.) Gas Release

The following table no. (19) Show that:

Table (19) Dispersion Modeling for Outlet - 10" Gas Release

Gas Release					
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)	
3.14 D	UFL	17.82	1.80	1.60	
	LFL	18.30	0 – 3.70	3.70	
	50 % LFL	18.40	0 – 4.40	4.40	
Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	66.34	1.6	142.30	85.30	0
		4	95.20	53.60	0
		9.5	65	32.40	0
		12.5	58.40	26.60	20% /60 sec.
		25	44.70	14.35	80.34
		37.5	16.20	9.25	98.74
Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	64	N/D	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	16	N/D	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	12	N/D	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>
Fireball					
Wind Category	Heat Radiation (kW/m ²)	Distance (m)	Heat Radiation (kW/m ²) Effects on People & Structures		
3.14 D	1.6	32	12.5		
	4	19	<i>20 % Chance of fatality for 60 sec exposure</i>		
	9.5	10	25		
	12.5	8	<i>100 % Chance of fatality for continuous exposure</i>		
	25	Not Reached	<i>50 % Chance of fatality for 30 sec exposure</i>		
	37.5	Not Reached	37.5 <i>Sufficient of cause process equipment damage</i>		




Figure (25) Gas Cloud Side View (UFL/LFL) (10" Outlet Pipeline Full Rupture)

- The previous figure shows that if there is a gas release from 10" pipeline full rupture without ignition the flammable vapors will reach a distance more than 18 m downwind and over 4.40 m height.
- The UFL will reach a distance of about 17.82 m downwind with a height of 1.80 m. The cloud large width will be 1.60 m crosswind.
- The LFL will reach a distance of about 18.30 m downwind with a height from 0 to 3.70 m. The cloud large width will be 3.70 m crosswind.
- The 50 % LFL will reach a distance of about 18.40 m downwind with a height from 0 to 4.40 m. The cloud large width will be 4.40 m crosswind.

The modeling shows that the gas cloud effects will extend outside the PRMS southeast fence downwind.




Figure (26) Heat Radiation Contours from Jet Fire (10" Outlet Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 10" pipeline full rupture and ignited the expected flame length is about 66.34 meters downwind.
- The 9.5 kW/m² heat radiation contours extend about 65 meters downwind and 32.40 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 58.40 meters downwind and 26.60 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 44.70 meters downwind and 14.35 meters crosswind.
- The 37.5 kW/m² heat radiation contours extend about 16.20 meters downwind and 9.25 meters crosswind.

The modeling shows that all radiation values will extend outside the PRMS boundary form southeast side with no effects.




Figure (27) Early Explosion Overpressure Waves (10" Outlet Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 10" pipeline full rupture and early ignited this will give an explosion with different values of overpressure waves.
- The 0.020 bar overpressure waves will extend about 64 meters radius.
- The 0.137 bar overpressure waves will extend about 16 meters radius.
- The 0.206 bar overpressure waves will extend about 12 meters radius.

The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside.

The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.




Figure (28) Heat Radiation Contours from Fireball (10" Outlet Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 10" pipeline full rupture and ignited forming fireball this will gives a heat radiation with different values and contours and will extend in four dimensions.
- The 9.5 kW/m² heat radiation contours extend about 10 meters radius.
- The 12.5 kW/m² heat radiation contours extend about 8 meters radius.
- The 25 kW/m² heat radiation not reached.
- The 37.5 kW/m² heat radiation not reached.

The modeling shows that the heat radiation values of 9.5 & 12.5 kW/m² will be limited inside the PRMS boundary effecting the PRMS facilities.



3.0- Pressure Reduction Station Odorant Tank (Spotleak)

The following table no. (20) Show 1" hole leak form odorant Modeling:

Table (20) Dispersion Modeling for Odorant Tank

Gas Release				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	17.92	0 – 0.25	12
	LFL	23.14	0 – 0.34	16
	50 % LFL	31.59	0 – 0.52	21

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	16.01	1.6	40.88	25.60	0
		4	30.60	16.40	0
		9.5	24.48	10.85	0
		12.5	23.10	9.40	20% /60 sec.
		25	19.80	6	80.34
		37.5	17.80	4.12	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	53	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	28	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	26	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>




Figure (29) Vapor Cloud (UFL/LFL) Side View Graph (Odorant leak)

- The previous figures show that if there is a leak from odorant tank without ignition the flammable vapors will reach a distance more than 31 m downwind and from 0 to 0.53 m height (the vapors heavier than air).
- The UFL ($2.1E+04$ ppm) will reach a distance of about 17.92 m downwind with a height from 0 to 0.25 m. The cloud large width will be 12 m crosswind.
- The LFL ($1.4E+04$ ppm) will reach a distance of about 23.14 m downwind with a height from 0 to 0.26 m. The cloud large width will be 16 m crosswind.
- The 50 % LFL (7000 ppm) will reach a distance of about 31.59 m downwind with a height from 0 to 0.53 m. The cloud large width will be 21 m crosswind.

The modeling shows that the vapor cloud will be limited inside the PRMS boundary and expanded around the PRMS facilities (heavier than air).

Consideration should be taken when deal with liquid, vapors and smokes according to the MSDS for the material.



Document Title: Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction & Metering Station




Figure (30) Heat Radiation Contours - Jet Fire Graph (Odorant Leak)




Figure (31) Heat Radiation Contours - Jet Fire on Site (Odorant Leak)

- The previous figure show that if there is a leak from the odorant tank and ignited the expected flame length is about 16 meters downwind.
- The 9.5 kW/m² heat radiation contours extend about 24.48 meters downwind and 10.85 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 23.10 meters downwind and 9.40 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 19.80 meters downwind and 6 meters crosswind.
- The 37.5 kW/m² heat radiation contours extend about 17.80 meters downwind and 4.12 meters crosswind.

The modeling shows that the heat radiation will be limited inside the PRMS boundary effecting the facilities and near to the firefighting facilities crosswind.



Document Title: **Quantitative Risk Assessment "QRA" Study For Farshout Pressure Reduction & Metering Station**




Figure (32) Late Explosion Overpressure Waves Graph (Odorant Leak)




Figure (33) Late Explosion Overpressure Waves on Site (Odorant Leak)



- The previous figure show that if there is a leak from the odorant tank and late ignited this will give an explosion with different values of overpressure waves.
- The 0.020 bar overpressure waves will extend about 53 meters downwind.
- The 0.137 bar overpressure waves will extend about 28 meters downwind.
- The 0.206 bar overpressure waves will extend about 26 meters downwind.

The modeling shows that all values will extend outside the PRMS boundary from the southeast side downwind with no effects.



4.0- Pressure Reduction Station Off-Take Pipeline (4 inch)

4/1- Consequence Modeling for 1 inch (Pin Hole) Gas Release

The following table no. (21) Show that:

Table (21) Dispersion Modeling for Off-take - 1" / 4" Gas Release

Gas Release				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	0.054	1.70	0.08
	LFL	0.32	2.90	0.42
	50 % LFL	0.75	3.70	0.90

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	4.18	1.6	10.80	5.75	0
		4	1.72	1.23	0
		9.5	Not Reached	Not Reached	0
		12.5	Not Reached	Not Reached	20% /60 sec.
		25	Not Reached	Not Reached	80.34
		37.5	Not Reached	Not Reached	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	N/D	0.021 bar	<i>Probability of serious damage beyond this point = 0.05 - 10 % glass broken</i>
	0.137	N/D	N/D	0.137 bar	<i>Some severe injuries, death unlikely</i>
	0.206	N/D	N/D	0.206 bar	<i>Steel frame buildings distorted / pulled from foundation</i>




Figure (34) Gas Cloud Side View (UFL/LFL) (1" hole in 4" off-take Pipeline)

- The previous figure shows that if there is a gas release from 1" hole size without ignition the flammable vapors will reach a distance about 0.75 m downwind and 3.70 m height.
- The UFL will reach a distance of about 0.054 m downwind with a height of 1.70 m. The cloud large width will be 0.08 m.
- The LFL will reach a distance of about 0.31 m downwind with a height of 3.50 m. The cloud large width will be 0.40 m.
- The 50 % LFL will reach a distance of about 0.75 m downwind with a height 4.70 m. The cloud large width will be 0.80 m.

The modeling shows that the gas cloud effects will be limited inside the off-take boundary.




Figure (35) Heat Radiation Contours from Jet Fire (1" hole in 4" off-take Pipeline)

- The previous figure show that if there is a gas release from 1" hole size and ignited the expected flame length is about 4.18 meters height.
- The 1.6 kW/m² heat radiation contours extend about 10.80 meters downwind and 5.75 meters crosswind.
- The 4 kW/m² heat radiation contours extend about 1.72 meters downwind and 1.23 meters crosswind.
- The 9.5 kW/m² heat radiation not determined.
- The 12.5 kW/m² heat radiation not determined.
- The 25 kW/m² heat radiation not determined.
- The 37.5 kW/m² heat radiation not determined.

The modeling shows that the heat radiation value of 1.6 kW/m² will be limited inside the off-take boundary with some extension outside downwind with no effects.

The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software as it is very small values.



4/2- Consequence Modeling for 2 inch (Half Rup.) Gas Release

The following table no. (22) Show that:

Table (22) Dispersion Modeling for Off-take - 2" / 4" Gas Release

Gas Release					
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)	
3.14 D	UFL	0.12	2.60	0.18	
	LFL	0.64	5.50	0.90	
	50 % LFL	1.50	7.50	1.80	

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	8.70	1.6	22.40	11.80	0
		4	4.90	3.80	0
		9.5	Not Reached	Not Reached	0.72
		12.5	Not Reached	Not Reached	20% /60 sec.
		25	Not Reached	Not Reached	80.34
		37.5	Not Reached	Not Reached	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	N/D	0.021 bar	Probability of serious damage beyond this point = 0.05 - 10 % glass broken
	0.137	N/D	N/D	0.137 bar	Some severe injuries, death unlikely
	0.206	N/D	N/D	0.206 bar	Steel frame buildings distorted / pulled from foundation




Figure (36) Gas Cloud Side View (UFL/LFL) (2" hole in 4" off-take Pipeline)

- The previous figure shows that if there is a gas release from 2" hole size without ignition the flammable vapors will reach a distance more than 1.50 m downwind and 7.50 m height.
- The UFL will reach a distance of about 0.12 m downwind with a height of 2.60 m. The cloud large width will be 0.18 m.
- The LFL will reach a distance of about 0.64 m downwind with a height of 5.50 m. The cloud large width will be 0.90 m.
- The 50 % LFL will reach a distance of about 1.50 m downwind with a height 7.50 m. The cloud large width will be 1.80 m.

The modeling shows that the gas cloud effects will be limited inside the off-take boundary.




Figure (37) Heat Radiation Contours from Jet Fire (3" hole in 6" off-take Pipeline)

- The previous figure show that if there is a gas release from 3" hole size and ignited the expected flame length is about 8.70 meters height.
- The 1.6 kW/m² heat radiation contours extend about 22.40 meters downwind and 11.80 meters crosswind.
- The 4 kW/m² heat radiation contours extend about 4.90 meters downwind and 3.80 meters crosswind.
- The 9.5 kW/m² heat radiation not determined.
- The 12.5 kW/m² heat radiation not determined.
- The 25 kW/m² heat radiation not determined.
- The 37.5 kW/m² heat radiation not determined.

The modeling shows that the heat radiation value of 1.6 will extend outside the off-take boundary from south, east and west sides with a few meters.

The modeling shows that the heat radiation value of & 4 kW/m² will extend outside the off-take boundary downwind with no effects.

The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software as it is very small values.



4/3- Consequence Modeling for 4 inch (Full Rup.) Gas Release

The following table no. (23) Show that:

Table (23) Dispersion Modeling for Off-take - 4" Gas Release

Gas Release				
Wind Category	Flammability Limits	Distance (m)	Height (m)	Cloud Width (m)
3.14 D	UFL	0.23	4.50	0.40
	LFL	1.34	11.50	1.50
	50 % LFL	3.30	16.20	3.90

Jet Fire					
Wind Category	Flame Length (m)	Heat Radiation (kW/m ²)	Distance Downwind (m)	Distance Crosswind (m)	Lethality Level (%)
3.14 D	23.61	1.6	35.40	24.50	0
		4	27.10	15.30	0
		9.5	22.20	8.90	0
		12.5	19.20	7.10	20% /60 sec.
		25	15.40	3.12	80.34
		37.5	8.20	1.30	98.74

Unconfined Vapor Cloud Explosion - UVCE (Open Air)					
Wind Category	Pressure Value (bar)	Over Pressure Radius (m)		Overpressure Waves Effect / Damage	
		Early	Late		
3.14 D	0.020	N/D	N/D	0.021 bar	Probability of serious damage beyond this point = 0.05 - 10 % glass broken
	0.137	N/D	N/D	0.137 bar	Some severe injuries, death unlikely
	0.206	N/D	N/D	0.206 bar	Steel frame buildings distorted / pulled from foundation

Fireball			
Wind Category	Heat Radiation (kW/m ²)	Distance (m)	Heat Radiation (kW/m ²) Effects on People & Structures
3.14 D	1.6	Not Determined	<u>12.5</u> 20 % Chance of fatality for 60 sec exposure
	4	Not Determined	<u>25</u> 100 % Chance of fatality for continuous exposure
	9.5	Not Determined	50 % Chance of fatality for 30 sec exposure
	12.5	Not Determined	
	25	Not Determined	<u>37.5</u> Sufficient of cause process equipment damage
	37.5	Not Determined	




Figure (38) Gas Cloud Side View (UFL/LFL) (4" off-take Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 4" pipeline full rupture without ignition the flammable vapors will reach a distance more than 3 m downwind and over 16 m height.
- The UFL will reach a distance of about 0.23 m downwind with a height of 4.50 m. The cloud large width will be 0.40 m.
- The LFL will reach a distance of about 1.34 m downwind with a height of 11.50 m. The cloud large width will be 1.50 m.
- The 50 % LFL will reach a distance of about 3.30 m downwind with a height of 16.20 m. The cloud large width will be 3.90 m.

The modeling shows that the gas cloud will be limited inside the off-take boundary.



Figure (39) Heat Radiation Contours from Jet Fire (4" off-take Pipeline Full Rupture)

- The previous figure show that if there is a gas release from 4" pipeline full rupture and ignited the expected flame length is about 23.61 meters height.
- The 9.5 kW/m² heat radiation contours extend about 22.20 meters downwind and 8.90 meters crosswind.
- The 12.5 kW/m² heat radiation contours extend about 19.20 meters downwind and 7.10 meters crosswind.
- The 25 kW/m² heat radiation contours extend about 15.40 meters downwind and 3.12 meters crosswind.
- The 37.5 kW/m² heat radiation contours extend about 8.20 meters downwind and 1.30 meters crosswind.

The modeling shows that the heat radiation values will extend outside the off-take boundary from southeast side downwind with no effects.



Individual Risk Evaluation

• Risk Calculation

All identified hazards should be subject to an evaluation for risk potential. This means analyzing the hazard for its probability to actually progress to loss event, as well as likely consequences of this event.

There are four steps to calculate risk, which determined as follows:

- 1- *Identify failure frequency (International Data Base)*
- 2- *Calculating the frequency against control measures at site by using Event Tree Analysis "ETA".*
- 3- *Identify scenarios probability.*
- 4- *Calculated risk to people regarding to the vulnerability of life loses.*

Basically, risk will be calculated as presented in the following equation:

Risk to people (Individual Risk – IR) =

Total Risk (Σ Frequency of fire/explosion) x Occupancy x Vulnerability

Where:

- Total risk *Is the sum of contributions from all hazards exposed to (fire / explosion).*
- Occupancy *Is the proportion of time exposed to work hazards. (Expected that x man the most exposed person to fire/explosion hazards on site. He works 8 hours shift/day)*
- Vulnerability *Is the probability that exposure to the hazard will result in fatality.*

As shown in tables (5 & 6) – (Page: 32 & 33) the vulnerability of people to heat radiation starting from 12 kW/m² will lead to fatality accident for 60 sec. Exposure and for explosion over pressure starting from 0.137 bar.

The modeling of the different scenarios shows that the heat radiation would be a result from release scenarios for all sizes of crack with some of explosion overpressure waves and according to the space size for the PRMS, all of the sequence will be determined for three values release (small, medium and large).

Calculating frequencies needs a very comprehensive calculations which needs a lot of data collecting related to failure of equipment's and accident reporting with detailed investigation to know the failure frequency rates in order to calculate risks from scenarios.

In this study, it decided that to use an International Data Bank for major hazardous incident data.

The following table (24) show frequency for each failure can be raised in pressure reduction station operations:



Table (24) Failure Frequency for Each Scenario

Scenario	Release Size	Failure Cause	Failure Rate
Gas Release from 1" / 4" Pipeline 1" / 10" Pipeline	<i>Small</i>	Internal Corrosion	$1.19E-05$
		External Corrosion	$3.55E-06$
		Maintenance Error	$2.28E-05$
		Corrosive Liquid or Gas	$4.84E-04$
		Total	$5.22E-04$
		Gas Release from 2" / 4" Pipeline 4" / 10" Pipeline	<i>Medium</i>
External Corrosion	$8.24E-06$		
Erosion	$4.85E-04$		
Total	$5.20E-04$		
Gas Release from 4" / 10" Pipeline Full Rupture	<i>Large</i>	Internal Corrosion	
External Corrosion		$1.61E-06$	
Weld Crack		$4.34E-06$	
Earthquake		$1.33E-07$	
Total		$1.16E-05$	
Spotleak (Odorant Tank)		<i>Medium</i>	<i>As a package</i>
			$1.25E-05$

Reference: Taylor Associates ApS - 2006

(Hazardous Materials Release and Accident Frequencies for Process Plant - Volume II / Process Unit Release Frequencies - Version 1 Issue 7)



- **Event Tree Analysis**

An event tree is a graphical way of showing the possible outcomes of a hazardous event, such as a failure of equipment or human error.

An ETA involves determining the responses of systems and operators to the hazardous event in order to determine all possible alternative outcomes.

The result of the ETA is a series of scenarios arising from different sets of failures or errors.

These scenarios describe the possible accident outcomes in terms of the sequence of events (successes or failures of safety functions) that follow the initial hazardous event.

Event trees shall be used to identify the various escalation paths that can occur in the process. After these escalation paths are identified, the specific combinations of failures that can lead to defined outcomes can then be determined.

This allows identification of additional barriers to reduce the likelihood of such escalation.

The results of an ETA are the event tree models and the safety system successes or failures that lead to each defined outcome.

Accident sequences represents in an event tree represent logical and combinations of events; thus, these sequences can be put into the form of a fault tree model for further qualitative analysis.

These results may be used to identify design and procedural weaknesses, and normally to provide recommendations for reducing the likelihood and/or consequences of the analyzed potential accidents.

Using ETA requires knowledge of potential initiating events (that is, equipment failures or system upsets that can potentially cause an accident), and knowledge of safety system functions or emergency procedures that potentially mitigate the effects of each initiating event.



The equipment failures, system upsets and safety system functions shall be extracted from the likelihood data presented before.

In the case of hydrocarbon release, the event tree first branch is typically represents "Early Ignition". These events are represented in the risk analysis as jet fire events.

This is because sufficient time is unlikely to elapse before ignition for a gas/air mixture to accumulate and cause either a flash fire or a gas hazard.

Subsequent branches for these events represent gas detection, fire detection, inventory isolation (or ESD) or deluge activation.

Delayed ignitions are typically represented by the fifth branch event. This is because, in the time taken for an ignition to occur, sufficient time is more likely to elapse for gas detection and inventory isolation.

The scenario development shall be performed for the following cases:

- Without any control measures
- With control measures

The event tree analysis outcomes can be classified into three main categories as follows:

"Limited Consequence"	<i>Indicates that the release has been detected and the inventory source has been isolated automatically.</i>
"Controlled Consequence"	<i>Indicates that the release has been detected but the source has not been isolated automatically. [Needs human intervention].</i>
"Escalated Consequence"	<i>Indicates that the release has not been detected and consequently the source has not been isolated.</i>

The event trees analysis for each scenario are presented in the below pages:



Table (25) Off-take 4" / Inlet 4" / Outlet 10" Pipeline Scenarios (Pin Hole Crack – 1" Release) – Event Tree Analysis

Release of Flammable Materials ⁽¹⁾	Immediate Ignition ⁽²⁾	Fire Detection ⁽³⁾	ESD System ⁽³⁾	Fire Protec. ⁽³⁾	Delayed Ignition ⁽²⁾	Outcomes	Frequency
5.22E-04	0.02	0.6	0.978	0.97	0.02		
5.22E-04	Yes 0.02	Yes 0.6	Yes 0.978	Yes 0.97		Controlled Jet fire	1.01E-05
				No 0.03		Not controlled jet fire	3.13E-07
	No 0.98	No 0.4	No 0.022	Yes 0.02		Escalated jet fire	4.18E-06
				No 0.98		Limited release	-----
	No 0.98	No 0.4	No 0.022	Yes 0.02		Large release	1.13E-05
				Yes 0.02		Escalated jet fire	1.02E-05
				No 0.98		Escalated release	5.01E-04

(1) Refer to QRA Study Page 89. (Taylor Associates ApS - 2006)

(2) Ref. Handbook Failure Frequencies 2009.

(3) Ref. OGP – Report No. 434 – A1 / 2010.

TOTAL

1.47E-05



Table (26) Off-take 4" / Inlet 4" / Outlet 10" Pipeline Scenarios (Half Rupture Release) – Event Tree Analysis

Release of Flammable Materials ⁽¹⁾	Immediate Ignition ⁽²⁾	Fire Detection ⁽³⁾	ESD System ⁽³⁾	Fire Protec. ⁽³⁾	Delayed Ignition ⁽²⁾	Outcomes	Frequency	
5.20E-04	0.02	0.6	0.978	0.97	0.02			
5.20E-04	Yes 0.02	Yes 0.6	Yes 0.978	Yes 0.97		Controlled Jet fire	<i>1.01E-05</i>	
				No 0.03		Not controlled jet fire	<i>3.12E-07</i>	
	No 0.98	No 0.4	No 0.022			Escalated jet fire	<i>4.16E-06</i>	
						Limited release	-----	
				Yes 0.02		Escalated jet fire	<i>1.02E-05</i>	
				No 0.98		Escalated release	<i>4.99E-04</i>	
							TOTAL	<i>1.46E-05</i>

(1) Refer to QRA Study Page 89. (Taylor Associates ApS - 2006)

(2) Ref. Handbook Failure Frequencies 2009.

(3) Ref. OGP – Report No. 434 – A1 / 2010.



Table (27) Off-take 4" / Inlet 4" Pipeline Scenarios (Full Rupture Release) – Event Tree Analysis

Release of Flammable Materials ⁽¹⁾	Immediate Ignition ⁽²⁾	Fire Detection ⁽³⁾	ESD System ⁽³⁾	Fire Protec. ⁽³⁾	Delayed Ignition ⁽²⁾	Outcomes	Frequency
1.16E-05	0.02	0.6	0.978	0.97	0.02		
1.16E-05	Yes 0.02	Yes 0.6		Yes 0.97		Controlled Jet fire	2.25E-07
				No 0.03		Not controlled jet fire	6.96E-09
		No 0.4				Escalated jet fire	9.28E-08
						Limited release	-----
	No 0.98		Yes 0.978			Large release	2.50E-07
						Escalated jet fire	2.27E-07
		No 0.022			Escalated jet fire	2.27E-07	
					Escalated release	1.11E-05	

(1) Refer to QRA Study Page 89. (Taylor Associates ApS - 2006)

(2) Ref. Handbook Failure Frequencies 2009.

(3) Ref. OGP – Report No. 434 – A1 / 2010.

TOTAL

3.27E-07



Table (28) Outlet 10" Pipeline Scenarios (Full Rupture Release) – Event Tree Analysis

Release of Flammable Materials ⁽¹⁾	Immediate Ignition ⁽²⁾	Fire Detection ⁽³⁾	ESD System ⁽³⁾	Fire Protec. ⁽³⁾	Delayed Ignition ⁽²⁾	Outcomes	Frequency
1.16E-05	0.04	0.6	0.978	0.97	0.04		
1.16E-05	Yes 0.04	Yes 0.6	Yes 0.978	Yes 0.97	0.04	Controlled Jet fire	4.50E-07
				No 0.03		Not controlled jet fire	1.39E-08
	No 0.96	No 0.4	No 0.022	Yes 0.04	0.96	Escalated jet fire	1.86E-07
						No 0.96	Limited release
	No 0.96	No 0.4	No 0.022	No 0.96	0.96	Large release	2.45E-07
						Yes 0.04	Escalated jet fire
	No 0.96	No 0.4	No 0.022	No 0.96	0.96	Escalated release	1.07E-05

(1) Refer to QRA Study Page 89. (Taylor Associates ApS - 2006)
 (2) Ref. Handbook Failure Frequencies 2009.
 (3) Ref. OGP – Report No. 434 – A1 / 2010.

TOTAL **6.45E-07**



Table (29) Odorant Tank Release – Event Tree Analysis

Release of Flammable Materials ⁽¹⁾	Immediate Ignition ⁽²⁾	Fire Detection ⁽³⁾	ESD System ⁽³⁾	Fire Protec. ⁽³⁾	Delayed Ignition ⁽²⁾	Outcomes	Frequency
1.25E-05	0.2	0.6	0.978	0.97	0.065		
1.25E-05	Yes 0.2	Yes 0.6		Yes 0.97		Controlled fire	<i>2.43E-06</i>
				No 0.03		Large fire	<i>7.50E-08</i>
		No 0.4	Escalated fire	<i>1.00E-06</i>			
	No 0.8		Yes 0.978		Limited leak	-----	
			No 0.022		Large leak	<i>2.20E-07</i>	
		Yes 0.065		Escalated fire	<i>6.50E-07</i>		
				No 0.935	Escalated leak	<i>9.35E-06</i>	

(1) Refer to QRA Study Page 89. (Taylor Associates ApS - 2006)
 (2) Ref. Handbook Failure Frequencies 2009.
 (3) Ref. OGP – Report No. 434 – A1 / 2010.

TOTAL ***1.13E-05***



The following table (30) show the total frequency for each scenario from ETA - Tables (25 to 29):

Table (30) Total Frequencies for Each Scenario

Source of Release	Total Frequency (ETA)
1" / 4" Off-Take Pipeline Pin Hole	1.47E-05
1" / 4" Inlet Pipeline Pin Hole	
1" / 10" Outlet Pipeline Pin Hole	
2" / 4" Off-Take Pipeline Half Rupture	1.46E-05
2" / 4" Inlet Pipeline Half Rupture	
4" / 10" Outlet Pipeline Half Rupture	
4" Off-Take Pipeline Full Rupture	3.27E-07
4" Inlet Pipeline Full Rupture	
10" Outlet Pipeline Full Rupture	6.45E-07
Odorant Tank 1" hole Leak	1.13E-05

The following table (31) summarize the risk events on workers / public:

Table No. (31) Summarize the Risk on Workers / Public (Occupancy)

Off-take 4" Pipeline Release Scenarios					
Event Exposure		Jet / Pool Fire (12.5 kW/m ²)		Explosion Overpressure (0.137 bar)	
		Workers	Public	Workers	Public
Pin Hole	1"	None	None	None	None
Half Rupture	2"	None	None	None	None
Full Rupture	4"	None	None	None	None
Inlet 4" Pipeline Release Scenarios					
Pin Hole	1"	None	None	None	None
Half Rupture	2"	None	None	None	None
Full Rupture	4"	None	None	None	None
Outlet 10" Pipeline Release Scenarios					
Pin Hole	1"	None	None	None	None
Half Rupture	4"	None	None	1 / 10 min (0.16)	None
Full Rupture	10"	1 / 10 min (0.16)	None	1 / 10 min (0.16)	None
Odorant Tank Release Scenario					
Small Leak	1"	1 / 10 min (0.16)	None	None	None

Therefore, the risk calculation will depend on total risk from these scenarios, and as per the equation page (87):

Risk to People (Individual Risk – IR) =

Total Risk (Σ Frequency of fire/explosion) x Occupancy x Vulnerability

Where:

- Total risk - is the sum of contributions from all hazards exposed to (fire / explosion).

(Frequencies of Scenarios from Table-30)

- Occupancy - is the proportion of time exposed to work hazards. (Expected that x man the most exposed person to fire/explosion hazards on site. He works 8 hours shift/day).

(As per client data, Farshout PRMS occupancy is 4 persons / 24 hours)

(As per site visit to PRMS and off-take point and due to the far distances, it was noted that there is no effects on public "Table 31")

- Vulnerability - is the probability that exposure to the hazard will result in fatality.


(Reference: Report No./DNV Reg. No.: 2013-4091/1/17 TLT 29-6 – Rev. 1)

As per modeling, it was noted that there is no effects from heat radiation or explosion overpressure waves on Farshout PRMS workers or the public (PRMS / Off-take) surrounding public. The IR will be calculated assuming that one worker (maintenance or inspection works) exposed to the risk for 10 min. as per the following table (32):



Table (32) Individual Risk (IR) Calculation for the PRMS Workers

Source of Event	Frequency 1	Heat Radiation kW/m ² & Overpressure	Vulnerability 2	Time Exposed 3	IR = 1 x 2 x 3
Gas Release from 4"/10" outlet pipeline	1.46E-05	Explosion 0.137	0.1 (Outdoor)	0.16 ^{1 Pers.}	2.34E-06
Gas Release from 10" outlet pipeline	6.45E-07	Fireball 12.5	0.7 (Outdoor)	0.16 ^{1 Pers.}	7.22E-08
		Explosion 0.137	0.1 (Outdoor)	0.16 ^{1 Pers.}	1.03E-08
Odorant tank 1" leak	1.13E-05	Jet Fire 12.5	0.7 (Outdoor)	0.16 ^{1 Pers.}	1.27E-06
TOTAL Risk for the Workers					3.69E-06





Summary of Modeling Results and Conclusion

As per results from modeling the consequences of each scenario, the following table summarize the study, and as follows:

Event	Scenario	Effects
Pin hole (1") gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will be limited inside the PRMS boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value of 1.6 & 4 kW/m² will be limited inside the PRMS boundary. The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software due to small amount of the gas released.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>N/D</i>
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>N/D</i>
Half Rupture (2") gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud (50 % LFL) will extend outside the PRMS from the east side downwind with no effects.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the values of 9.5, 12.5 & 25 kW/m² will extend outside the PRMS southeast fence downwind with no effects inside or outside.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>N/D</i>
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS facilities with some extension outside. The values of 0.137 and 0.206 bar will extend outside the PRMS southeast fence with no effects.</i>



Event	Scenario	Effects
Full Rupture gas release 4" inlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects (LFL & 50 % LFL) will extend to reach the SE boundary downwind.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that all heat radiation values will extend outside the PRMS from southeast side with no effects inside.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020, 0.137 & 0.206 bar will extend outside the PRMS boundary from southeast side with no effects.</i>
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	N/D
Pin hole (1") gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud will be limited inside the PRMS boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value 1.6, 4 & 9.5 kW/m² effects will be limited inside the PRMS boundary downwind with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D



Event	Scenario	Effects
Half Rupture (4") gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud (UFL, LFL & 50% LFL) will extend outside the PRMS southeast fence with no effects.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation values of 9.5, 12.5, 25 & 37.5 kW/m² will extend outside the PRMS southeast fence with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside. The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.</i>
	Late explosion 0.020 bar 0.137 bar 0.206 bar	<i>N/D</i>
Full Rupture gas release 10" outlet pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will extend outside the PRMS southeast fence downwind.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that all radiation values will extend outside the PRMS boundary form southeast side with no effects.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	<i>The modeling shows that the value of 0.020 bar will cover the PRMS components and extend outside the boundary from all sides with no effects outside. The values of 0.137 bar and 0.206 bar will be limited inside the PRMS boundary and near to the firefighting facilities crosswind with some extension outside from southeast side.</i>



Event	Scenario	Effects
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	The modeling shows that the heat radiation values of 9.5 & 12.5 kW/m ² will be limited inside the PRMS boundary effecting the PRMS facilities.
Odorant tank 1" leak		
	Gas cloud UFL LFL 50 % LFL	The modeling shows that the vapor cloud will be limited inside the PRMS boundary and expanded around the PRMS facilities (heavier than air). Consideration should be taken when deal with liquid, vapors and smokes according to the MSDS for the material.
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	The modeling shows that the heat radiation will be limited inside the PRMS boundary effecting the facilities and near to the firefighting facilities crosswind.
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	The modeling shows that all values will extend outside the PRMS boundary from the southeast side downwind with no effects.
Pin hole (1") gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	The modeling shows that the gas cloud effects will be limited inside the off-take boundary.
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	The modeling shows that the heat radiation value of 1.6 kW/m ² will be limited inside the off-take boundary with some extension outside downwind with no effects. The values of 9.5, 12.5, 25 & 37.5 kW/m ² not determined by the software as it is very small values.



Event	Scenario	Effects
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
Half Rupture (2") gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud effects will be limited inside the off-take boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation value of 1.6 will extend outside the off-take boundary from south, east and west sides with a few meters. The modeling shows that the heat radiation value of & 4 kW/m² will extend outside the off-take boundary downwind with no effects. The values of 9.5, 12.5, 25 & 37.5 kW/m² not determined by the software as it is very small values.</i>
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
Full Rupture gas release 4" off-take pipeline		
	Gas cloud UFL LFL 50 % LFL	<i>The modeling shows that the gas cloud will be limited inside the off-take boundary.</i>
	Heat radiation / Jet fire 9.5 kW/m ² 12.5 kW/m ²	<i>The modeling shows that the heat radiation values will extend outside the off-take boundary from southeast side downwind with no effects.</i>



Event	Scenario	Effects
	Early explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Late explosion 0.020 bar 0.137 bar 0.206 bar	N/D
	Heat radiation / Fireball 9.5 kW/m ² 12.5 kW/m ²	N/D

The previous table shows that there are some of potential hazards with heat radiation (12.5 kW/m²) resulting from jet fire and explosion overpressure waves (0.137 bar) from late explosion events (Described in table 31).

These risks (Jet fire & Explosion overpressure waves) may affects worker at the PRMS (assuming that one person works in maintenance or inspection). In addition, it was noted that there is no effects from off-take point on surrounding area.

Regarding to risk calculations; the risk to Workers found in Acceptable, so there are some points need to be considered to keep the risk tolerability and this will be describe in the study recommendations.



Recommendations

As per results from modeling, the consequences of each scenario and risk calculations (as risks found in Acceptable region) and to keep the risk as found, it is recommended that:

- Ensure that
 - All PRMS facilities specifications referred to the national and international codes and standards.
 - Inspection and maintenance plans and programs are according to the manufacturers guidelines to keep all facility parts in a good condition.
 - All operations are according to standard operating procedures for the PRMS operations and training programs in-place for operators.
 - Emergency shutdown detailed procedure including emergency gas isolation points at the PRMS and Off-Take Point in place.
 - Surface drainage system is suitable for containment any odorant spillage.
- Considering that all electrical equipment, facilities and connections are according to the hazardous area classification for natural gas facilities.
- Review the emergency response plan and update the plan to include all scenarios in this study and other needs including:
 - Firefighting brigades, mutual aids, emergency communications and fire detection / protection systems.
 - Dealing with the external road in case of major fires.
 - First aid including dealing with the odorant according to the MSDS for it, with respect of means of water supply for emergency showers, eye washers and cleaning.
 - Provide the site with SCBA "Self-Contained Breathing Apparatus (at least two sets) and arrange training programs for operators.
 - Emergency shutdown detailed procedure including shut-off points at the PRS and GASCO main line.
 - Safe exits in building according to the modeling in this study.
- Provide a suitable tool for wind direction (Windsock) to be installed in a suitable place to determine the wind direction (the PRMS lay-out need to be reviewed for wind direction correction)
- Cooperation should be done with the concerned parties before planning for housing projects around the PRMS area.